



सत्यमेव जयते

Government Of West Bengal
Office Of The Divisional Fire Officer, North 24 Parganas
West Bengal Fire & Emergency Services
Ghoshpara Road, P.O.:- Bengal Enamel, Pin :- 743122

Memo no.: IND/WB/FES/20192020/85591

Date: 13-04-2023

From:

Divisional Fire Officer, North 24 Parganas
West Bengal Fire & Emergency Services

To: HARADHAN ADDHYA MEMORIAL SCHOOL

HARADHAN ADDHYA MEMORIAL SCHOOL, MOUZA - CHHAIGHARA, P.S - PETRAPOL, DIST - 24PGS(N), PIN-743704. Bongaon F.S., Bongaon, North 24 Parganas - 743704

Sub: Renewal Fire Safety Certificate for existing construction of G+II storied building under group Educational in the name & style of "HARADHAN ADDHYA MEMORIAL SCHOOL". at the premises no.- MOUZA - CHHAIGHARA, P.S - PETRAPOL, DIST - 24PGS(N), PIN-743704. Bongaon F.S., Bongaon, North 24 Parganas – 743704.

This is in reference to your application no. 0125191231100327 dated 23-03-2023 regarding the Renewal Fire Safety Certificate for existing construction of G+II storied building under group Educational in the name & style of "HARADHAN ADDHYA MEMORIAL SCHOOL". at the premises no.- MOUZA - CHHAIGHARA, P.S - PETRAPOL, DIST - 24PGS(N), PIN-743704. Bongaon F.S., Bongaon, North 24 Parganas – 743704.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

However to up-keep the Fire Safety Measures of the aforesaid building the following safety measures need to be incorporated / maintained.

- 1) Driveway must be free from any type of obstruction for EASY movement of fire appliances, No parking will be allowed on the driveway,
- 2) The interior finish decoration of buildings shall be made with low flame spread materials confirming I.S Specifications,
- 3) To eliminate risk of fire hazards, good housekeeping both for inside and outside of the building shall be strictly maintained,
- 4) Existing electrical wirings of the whole building shall have to be carefully checked for any wear and tear in them,

- 5) The notice of fire fighting and evacuation from the building shall be prepared and displayed at all vulnerable places of the building,
- 6) The employees and the security staffs shall be conversant with the installed fire fighting equipment of the building and to operate in the event of fire and testing,
- 7) Mock fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building,
- 8) First aid fire fighting system shall be provided as per IS specification and shall be checked or renewed once in every year,
- 9) Arrangements shall have to made for regular checking and testing of fire fighting measures in the building to keep them perfectly in working condition at all times,
- 10) The fire safety audit to be conducted at regular interval and to be recorded in the fire prevention maintenance register,
- 11) Floor no. with proper exit signage shall be marked at all floors of the building,
- 12) This Renewal Fire Safety Certificate is valid for 3 (three) years and have to be renewed every 3 (three) year from the date of issue of this letter
- 13) Any deviation / changes of the building in respect of approved plan drawing without prior permission from this office, this Fire Safety Certificate will be treated as cancelled.

Divisional Fire Officer, North 24 Parganas
West Bengal Fire & Emergency Services

Memo No.: IND/WB/FES/20192020/85391